



Conservation and Water Stewardship
Office of Drinking Water
1129 Queens Ave, Brandon, MB R7A 1L9
T 204-570-1405 F 204-726-6567
Christine.Gerardy@gov.mb.ca
www.manitoba.ca/drinkingwater



PWS 49.50

March 3, 2015

Reeve and Council
Rural Municipality of Victoria
Box 40
Holland MB R0G 0X0

2014 Annual Compliance Audit

Dear Reeve and Council:

Please find enclosed the 2014 Annual Compliance Audit for the Cypress River public water system (PWS). The report compares water system compliance to *The Drinking Water Safety Act* and its supporting regulations, and the terms and conditions of the water system's current operating licence (PWS-08-241-01).

Please note the Office of Drinking Water has changed the Annual Compliance Audit format to allow for a more streamlined automated process. The new format contains a summary and a detailed addendum of non-compliance items that have been identified for your water supply throughout the year. If there have been no occurrences of non-compliance the summary will simply indicate 'none reported'.

Where non-compliance items are identified, this format provides a clear description of areas that the water system needs to improve on in the interest of public health. It should be noted that non-compliance issues do not necessarily translate into increased public health risk. Where the risks to the public are such that the public needs to be notified, the Office of Drinking Water would work with the water system to notify water users through boil water advisories and other similar processes.

Please note that as per the terms and conditions of your operating licence the following documentation is required:


- Engineering Re-Assessment (due date: March 1, 2016)

Water suppliers are reminded to immediately notify the Office of Drinking Water of any condition(s) that may affect the ability of the water system to produce or deliver safe drinking water. These conditions include:

- treatment upsets or bypass conditions (including operation outside of licence conditions)
- contamination of source or treated water
- a disinfection, filtration or distribution system failure

The 2014 Annual Compliance Audit is based on information submitted to this office. If your records conflict with the audit information, or if you have any questions concerning this report, or any other drinking water related issues, please call me at (204) 570-1405.

Sincerely,


Christine Gerardy
Drinking Water Officer

Enclosures

e-copy: Ivan Bruneau, CAO
copy: Neil Young, Operator

2014 Annual Compliance Audit

Water System: CYPRESS RIVER - PWS

Code: 49.50

Water System Owner: Rural Municipality of Victoria

Water System Operating Licence: PWS-08-241-01

Expiry Date: November 30, 2018

- 1) This report documents the Cypress River Public Water System compliance for the period from January 1 to December 31, 2014.
- 2) Addendum A to this report provides specific information on the non-compliance incidents identified in the summary below.
- 3) Other than the information provided in attached Addendum A, the water supplier has complied with *The Drinking Water Safety Act*, its supporting regulations, and the terms and conditions of the water system's current operating licence
- 4) This report is based on information submitted by the water supplier, agents of the water supplier, and / or the Province of Manitoba.

Summary of Non-Compliance Incidents:

- | |
|--|
| <ul style="list-style-type: none">• Failure to Meet Bacteriological Requirements |
|--|

Addendum A: Record of Non-Compliance

Water System: CYPRESS RIVER - PWS

Report period: January 1, 2014 to December 31, 2014.

Enforcement Action Taken

Date	Clause	Incident	Outcome
		None reported	

Disinfection Requirements

Date	Samples	Incident	Outcome
		None reported	

Bacteriological Requirements

Date	Samples	Incident	Outcome
2014/03/10	1	Failure to meet Bacteriological Standard: Total Coliform (TC) detected	Non-compliant Result Reported to the Office of Drinking Water

Microbial Requirements

Date	Clause	Incident	Outcome
		None reported	

Turbidity Requirements

Date	Samples	Incident	Outcome
		None reported	

Chemical Requirements

Date	Clause	Incident	Outcome
		None reported	

Operational Requirements

Date	Clause	Incident	Outcome
		None reported	